

STORMWATER MANAGEMENT

410-887-3768

July 30, 2019

ENEngineering
808 Landmark Drive, Suite 217
Quarterfield Center
Glen Burnie, MD 21061
Attn: Palm Kompayak, P.E.

RE: BGE Halethorpe Phase I
Stormwater Management Variance
Patapsco River Watershed
EPS Project I.D. M190165
EPS Tracking Number: 01-19-3049

Dear Mr. Kompayak:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the upgrading of gas mains by cut and cover. The existing cover conditions will be reestablished once the project is completed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Michael P. Doyle of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Kritty Udhin, P.E., Manager
Stormwater Management
Department of Environmental Protection
& Sustainability

KU:jcm

c: Michael P. Doyle